



NOTES:

1. LENGTH OF EXTENSION OF PIPE AND RESTRAINED JOINTS SHALL BE IN ACCORDANCE WITH THESE ENGINEERING STANDARDS.
2. CATHODIC PROTECTION SHALL BE AS REQUIRED IN ACCORDANCE WITH THESE ENGINEERING STANDARDS.
3. A BORED CROSSING MAY BE REQD BY THE ENGINEER.

DENVER WATER

1800 West 12th Avenue • Denver, Colorado 80204
Phone (303) 628-6000 • Telecopier No. (303) 628-6851

**OPEN CUT CROSSING BENEATH
CONDUIT OR CONFLICTING UTILITY**

Scale: NONE Date: JULY 1995

Drawn: C.B.B. Tr: Ck:

Approved: *[Signature]* Dr. 127 No. 35